# Faldes





#### **PLATE EXCHANGER**

High-efficiency polymeric membrane counter-flow ERV

#### **CASING** (Standard)

Material: 24-gauge galvanized steel Drain connections: optional Duct connections: 5"(127 mm) Insulation: EPS molded polystyrene

Length: 23" (584.2 mm) Height: 19" (482.6 mm) Width: 16" (406.4 mm) Weight: 49 lb (22 kg)

Exhaust Damper: Closed by gravity Fresh air Damper: Motorized

Swivel ports for horizontal, vertical, oblique or mixed

installations.



#### **MOUNTING**

Mounting chains included Wall mounting optional (P/N 699921)



#### **ELECTRICAL SPECIFICATIONS**

120 V, 60 Hz, 145 W, 2.46 A



### **FILTERS**

(Standard)

Quantity:

2 washable MERV 6 filters (P/N 699771) Optional filter types: MERV 8 (P/N 699772), MERV 13 (P/N 699881)

## **InspirAIR® ELITE**

## ERV

## EK150-TQX

154 CFM at 0.4 in.w.g

**BLOWERS & MOTORS** 

















Two motorized impellers (backwards inclined)
Quick-connect motors for easy and efficient maintenance
EC motor

## DEFROST



Automatic Programmed Recirculation: Cycles are controlled by a temperature sensor when the outside temperature drops below 17.6°F (-8°C).

#### WARRANTY

Limited 5 years on the cores and all covered components.

## WALL CONTROLS

Low voltage dry contact (24VAC) for interlock with heating and cooling systems. For more details, please refer to the wall control specification sheets.



Digital Multifunction Control (P/N 611242-FC)



LCD Electronic Multifunction Control (P/N 611227)



20/40/60 Minute Timer (P/N 611228)




Speed Control (Low/Intermittent/High) (P/N 611229)




Mode Control (Recirculation) (P/N 611230)




## Page 2 | EK150-TQX



## FRONT VIEW




## SIDE VIEW



## **EK150-TQX: PERFORMANCE**

## **EK150-TQX Ventilation Performance**



Thermal Performance – EK150-TQX									
Supply Tem- perature		Net Airflow		Power Consu- med	Sensible Recovery	Adjusted Sensible	Latent Recovery/	Total Recovery	
°F	°C	CFM	L/s	(w)	Efficiency	Recovery Efficiency	Moisture Transfer	Efficiency	
Heating									
32	0	50	23	23	83%	86%	74%	-	
32	0	65	31	29	83%	86%	73%	-	
-13	-25	67	31	50	75%	77%	71%	-	
Cooling									
95	35	65	31	29	-	-	88%	83%	

Project:	Architect:
Location:	Engineer:
Model #:	Contractor:
Quantity:	Comments:
Submitted By:	
Date:	



